

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

TEST REPORT

Client : Godfrey Hirst Aust Pty Ltd
7 Factories Road
South Geelong VIC 3220

Test Number : 21-003856
Issue Date : 23/09/2021
Print Date : 23/09/2021
Order Number : AW 7U

Sample Description Clients Ref : "36oz 100% SDN Cut Pile Carpet"
Cut Pile Carpet - Action Bac Backing 100% Solution Dyed Nylon

AS ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 28-07-2021

Date Tested 22-09-2021

CHF Value	1	2	3	Mean
Length	7.7	6.0	5.8	6.5 kW/m ²
Width	9.2	-	-	- kW/m ²

Smoke Value	1	2	3	Mean
Length	74	62	73	70 %.min
Width	55	-	-	- %.min

Melting Yes

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

HF30 not reported as flame out time occurred before 30 minutes.

250040

53228

Page 1 of 1

