

Emission Test Certificate

Monday 3rd February 2020

Supplier: Godfrey Hirst Australia (7 Factories Road, Geelong, VIC 3220, Australia)

Sample Description: GH HYB 1500 x 228 x 6.5mm Hybrid Plank

Date Tested: January 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data (24 hours):

Global GreenTag	GH HYB 1500 x 228 x 6.5mm Hybrid Plank
Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.043 mg/m ² /hr
4-phenylcyclohexene Emission Rate Limit: <0.05 mg/m ² /hr	4-phenylcyclohexene Emission Rate: <0.003 mg/m ² /hr
Formaldehyde Emission Rate Limit: <0.1 mg/m ² /hr	Formaldehyde Emission Rate: <0.003 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Luke Morley
BSc(Tech)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V2001024